Air Flow and Acoustic Research and Development Study of various Air Outlets



Report No. 30B-10-0406-TRP-595133-2

Vipac Engineers & Scientists Pty Ltd Melbourne, Australia July 2011





This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO/IEC 17025.



DOCUMENT CONTROL FORM

Air Flow and Acoustic Research and Development Study of various Air Outlets

Outlets								
FILE:								
30B-10-0406-TRP-595133-2								
PREPARED FOR:	PREPARED BY:							
Flex Dur Technology Sdn Bhd	Vipac Engineers & Scientists Ltd.,							
Lot 178, Jalan Industry 3/6	Victorian Technology Centre,							
Rawang Integrated Industrial Park,	275 Normanby Road,							
48000 Rawang, Selangor Darul, Ehsan	Port Melbourne VIC. 3207							
	AUSTRALIA							
Contact Name: Ng Fui Leong								
Phone: (+603) 6091 6666	Phone: (613) 9647-9755							
Fax: (+603) 6092 1367	Fax: (613) 9646-4370							

AUTHOR:		
	By well -	20/7/2011
	Bryan Dalziel	Date: July 2011
	Project Engineer	
REVIEWED BY:	Q:è	20/7/2011
	Zarko Drinic	Date: July 2011
	N.A.T.A. Signatory	
REVISION HISTORY:		
Issue No.	Date Issued	Reason/Comments
2	July 2011	Additional Data
DISTRIBUTION:		
This is Copy No.	Issue No.	Location
1	2	Client
2	0	Project File
3	0	Vipac Melbourne Library
KEY WORDS:	Air Flow, Pressure, No	oise

Ref: 30B-10-0406-TRP-2

NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



TABLE OF CONTENTS

DOC	CUMENT CONTROL FORM	2
1.0	INTRODUCTION	4
2.0	TEST SPECIMEN	4
3.0	TEST CONDITIONS AND APPLICABLE STANDARDS	11
4.0	TEST SET UP AND SPECIFICATION	12
5.0	INSTRUMENTATION	15
6.0	ORDERS OF ACCURACY	16
7.0	RESULTS	17



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.





1.0 INTRODUCTION

This report presents the results of acoustic and airflow development tests carried out on nineteen (19) Diffusers supplied by Flex Dur Technology Sdn Bhd, as described below.

This report is issued as a NATA certified report under the terms of Vipac's NATA accreditation No 676.

2.0 TEST SPECIMEN

The units under test are detailed in Table 1 below.

Table 1: Units Under Test

#	Test Item	Model	Face Dimensions (mm)	Plenum Box Face Dimensions (mm)	Plenum Box Neck Dimensions (mm)
1	4-way Diffuser	CSD – A	595 x 595	481 x 481 x 200	Ø145mm
2	4-way Diffuser	CSD – A	595 x 595	481 x 481 x 200	255mm x 105mm
3	4-way Diffuser	CSD – A	595 x 595	481 x 481 x 200	315mm x 135mm
4	4-way Diffuser	CSD – A	595 x 595	481 x 481 x 200	380mm x 180mm
5	4-way Diffuser	CSD – A	595 x 595	481 x 481 x 250	420mm x 220mm
6	Swirl Diffuser	CSW - S	595 x 595	550 x 550 x 200	Ø145mm
7	Swirl Diffuser	CSW - S	595 x 595	550 x 550 x 200	255mm x 105mm
8	Swirl Diffuser	CSW - S	595 x 595	550 x 550 x 200	315mm x 135mm
9	Swirl Diffuser	CSW - S	595 x 595	550 x 550 x 200	380mm x 180mm
10	Swirl Diffuser	CSW – S	595 x 595	550 x 550 x 250	420mm x 220mm
11	Air Light Troffer (2-sides)	CCLT - S - D	1200 x 600	N/A	250mm x 120mm
12	Air Light Troffer (4-sides)	CCLT-S-Q	600 x 600	N/A	388mm x 160mm
13	Round Diffuser	CRC – A	Ø200 (Neck Size)	N/A	N/A
14	Round Diffuser	CRC – A	Ø250 (Neck Size)	N/A	N/A
15	Round Diffuser	CRC – A	Ø300 (Neck Size)	N/A	N/A
16	Linear Bar Grille	LFB – A	900 x 95	N/A	N/A
17	Linear Slot Diffuser (2-slots)	LFS – A	128 x 1200 x 2	182 x 116 x 1197	260mm x 112mm
18	Linear Slot Diffuser (3-slots)	LFS – A	175 x 1200 x 3	182 x 162 x 1197	315mm x 135mm
19	Double Deflection Grille	RVD – A	600 x 200	N/A	N/A

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



Figures 1 –17 show the test samples:



Figure 1: Test Unit No.1 – Swirl Diffuser with Plenum Box (145mm dia. Neck)





Figure 2: Test Unit No.2 - Swirl Diffuser with Plenum Box (255x105mm neck)



Figure 3: Test Unit No.3 - Swirl Diffuser with Plenum Box (315x130 mm neck)





NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.




Figure 4: Test Unit No.4 – Swirl Diffuser with Plenum Box (380x180mm neck)




Figure 5: Test Unit No.5 – Swirl Diffuser with Plenum Box (420x220mm neck)




Figure 6: Test Unit No.6 – 4-way Diffuser with Plenum Box (145 mm dig. Neck)



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

Commercial-in-Confidence




Figure 7: Test Unit No.7 – 4-wayDiffuser with Plenum Box (255x105mm neck)




Figure 8: Test Unit No.8 – 4-way Diffuser with Plenum Box (315x130mm neck)



Figure 9: Test Unit No.9 – 4-way Diffuser with Plenum Box (380x180mm neck)



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

2



Figure 10: Test Unit No.10 - 4-way Diffuser with Plenum Box (420x220mm neck)



Figure 11: Test Unit No.11 -Air Light Troffer - 2 Sides




Figure 12: Test Unit No.12 -Air Light Troffer - 4 Sides



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

0




Figure 13: Test Units No.13, 14 & 15 – Round Diffusers (left to right) 300, 250 & 200 mm diameter.




Figure 14: Test Unit No.16 - Linear Bar Grille



Figure 15: Test Unit No.17 - Linear Slot Diffuser (2 Slots)



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.





Figure 16: Test Unit No.18 - Linear Slot Diffuser (3 Slots)



Figure 17: Test Unit No.19 - Double Deflection Grille



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



3.0 TEST CONDITIONS AND APPLICABLE STANDARDS

3.1 TEST CONDITIONS

The units under test were supplied with ambient temperature air at the following conditions:

Test Air Temperature	17 degrees C	± 2.0 degree C
Room Air Temperature	19 degrees C	± 2.0 degree C
Barometric Pressure	1020 millibar	± 5 millibar
Relative Humidity	55	<u>+</u> 10%

3.2 APPLICABLE STANDARDS

The units were tested at a range of flow conditions, as shown on the Test Certificates.

The test set up was in general accordance with ANSI/ASHRAE 70-2006. Measurements were taken in general accordance with the following standards:

ACOUSTICS

AS1217.2 Acoustics - Determination of sound power levels of noise sources Part 2: Precision methods for broad-band sources in reverberation rooms.

AIRFLOW

ANSI/ASHRAE 70-2006, Method of Testing the performance of Air Outlets and Air Inlets

THROW & STATIC PRESSURE DROP

ANSI/ASHRAE 70-2006, Method of Testing the performance of Air Outlets and Air Inlets







4.0 TEST SET UP AND SPECIFICATION

Vipac's Reverberation Test Room has a volume of 170m³ has been qualified in accordance with the procedures in AS 1217.2 - 1985 for determination of sound power in octave bands with Centre Frequencies from 125 Hz to 8000 Hz.

The units under test were set up in the Air Distribution (Reverberation) Test Chamber and connected to a quiet air supply.

Adjustments on the blade angle/position of each light troffers and slot diffusers were set to ensure maximum horizontal throw where possible. (See Figures 18).

Following calibration checks, sound pressure levels were measured and converted to sound power levels using the comparison method of AS1217.2 - 1985 (ie. using a reference sound source of known Sound Power to determine room correction).

Airflow rates were measured using \emptyset 150 mm orifice plate. Static pressure drop was recorded using a (Static Pressure) probe and a digital manometer. Throw was measured using a hotwire type anemometer.

Figures 18 to 25 show the test setups:




Figure 18: Test Set-up (Slot Diffuser Blade Angles to produce maximum horizontal flow)




Figure 19: Test Set-up (Light Troffer Blade Angles)

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.








Figure 20: Test Set-up (Test Samples 1-5)




Figure 21: Test Set-up (Test Samples 6 - 10)

NATA

NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.








Figure 22: Test Set-up (Test Samples 17 & 18)




Figure 23: Test Set-up (Test Samples 11 & 12)

NATA

NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

9






Figure 24: Test Set-up (Test Samples 16 & 19




Figure 25: Test Set-up (Test Samples 13, 14 & 15)

NATA

NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

2



5.0 INSTRUMENTATION

INSTRUMENT	MAKE & MODEL	CALIB	CALIBRATION			
		BY	DATE			
Sound Level Meter	ONO SOKKI LA-5570	Vipac	Feb 2011	47958 / 20627		
Microphone	MI-3310	Vipac	Feb 2011	21367		
Acoustic Calibrator	B&K 4230	Vipac	Feb 2011	831145		
Manometer	TSI DP-Calc	TSI	Dec 2010	000010147		
Orifice Plates	Vipac	Vipac	May 2001	-		
Hotwire Anemometer	TSI 9545-A	TSI	Feb 2011	9545A0813010		

6.0 ORDERS OF ACCURACY

Sound Pressure Level:	Octave Band Centre	Standard Deviation (1)
	Frequency (Hz)	(dB)
	125	<u>+</u> 3.0
	250	<u>+</u> 2.0
	500 to 4000	<u>+</u> 1.5
	8000	<u>+</u> 3.0

Pressure Drop:

+ 5% or 0.5 Pa whichever is greater

Airflow:

± 5% or 10 l/s whichever is greater





NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



7.0 RESULTS

The results obtained are shown in the attached Test Certificates.

Report Prepared by:

VIPAC ENGINEERS AND SCIENTISTS LTD.

BRYAŃ DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

July 2011

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

TESTED BY:

TEST DATE:

CLIENT:

UNIT/MODEL:

DIFFUSER SIZE: PLENUM SIZE:

NECK (INLET) SIZE:

FLEX DUR TECHNOLOGY SDN BHD

VIPAC ENGINEERS & SCIENTISTS PTY LTD

MARCH 2011

FLEX DUR TECHNOLOGY SDN BHD

4-way Diffuser and Plenum Box / CSD - A

595mm x 595mm

481 mm x 481 mm x 200 mm

Ø 145mm

TEST CON	NDITIONS				POWER L					
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)			-					
81	21	2.9	18	<44.4	<36.1	33.9	29.4	21.2	<16.1	<11.4
97	30	3.5	24	<45.0	40.4	39.2	34.6	28.8	19.3	<11.6
119	44	4.4	30	46.8	45.1	44.8	40.7	36.3	28.2	<13.4
147	64	5.5	35	49.5	51.0	49.3	45.3	42.4	35.6	18.0
185	100	7.0	41	55.3	56.0	55.3	51.9	49.8	43.8	28.2

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT: UNIT/MODEL:

FLEX DUR TECHNOLOGY SDN BHD 4-way Diffuser with Plenum Box / CSD - A

DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 481 mm x 481 mm x 200 mm Oval Neck: 255mm x 105mm

TEST CON	DITIONS				POWER L					
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
	(, a)	(/								
121	18	5.1	19	<44.1	37.3	34.6	27.7	20.3	<14.5	<10.5
138	24	5.8	24	<45.2	41.7	39.4	34.2	28.0	18.1	<10.6
178	40	>7	31	47.3	48.1	46.3	41.9	37.2	28.6	<12.4
210	54	>7	36	50.5	52.8	50.9	46.6	43.3	35.8	18.3
252	82	>7	42	55.0	57.7	56.6	52.3	49.9	43.3	27.5

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

- Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT: UNIT:

FLEX DUR TECHNOLOGY SDN BHD 4-way Diffuser with Plenum Box / CSD - A

DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 481 mm x 481 mm x 200 mm Oval Neck: 315mm x 135mm

TEST CON	NDITIONS			A A A A A A A A A A A A A A A A A A A	POWER L					
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
148	2	6.9	18	<44.5	37.1	34.0	27.0	19.4	<14.8	<11.1
189	5	>7	25	<45.8	43.2	40.8	36.0	29.8	20.2	<11.6
224	8	>7	31	47.9	48.6	46.4	41.9	37.3	29.1	<13.0
266	12	>7	38	52.9	54.3	51.8	48.1	44.8	37.8	20.2
317	20	>7	42	56.2	57.8	56.2	52.5	50.1	44.0	28.0

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL
PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ViPAC

TEST CERTIFICATE No. 4

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

4-way Diffuser with Plenum Box / CSD - A

DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 481 mm x 481 mm x 200 mm Oval Neck: 380mm x 180mm

TEST CON	IDITIONS			SALES CONTRACTOR OF THE PARTY O	POWER L	and the same of the same				
				OCTAVE	BAND C	ENTRE FF	REQUEN	ICY (Hz)		
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
212	7	>7	21	<43.6	39.2	36.9	31.1	24.9	<17.2	<11.7
251	9	>7	26	45.4	43.5	41.1	35.8	30.3	21.9	<12.4
307	15	>7	32	50.0	50.3	46.9	42.3	38.3	31.0	16.5
363	22	>7	37	54.1	54.7	51.3	47.2	44.3	37.7	21.9
393	26	>7	40	57.0	57.9	54.8	50.7	48.3	42.5	27.3

LEGEND

Qs - Primary Air Flow Rate (L/s)Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT: UNIT:

FLEX DUR TECHNOLOGY SDN BHD 4-way Diffuser with Plenum Box / CSD - A

DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 481 mm x 481 mm x 250 mm Oval Neck: 420mm x 220mm

TEST CON	IDITIONS				POWER L					
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
198	2	>7	18	<44.3	39.4	33.8	28.4	23.5	<17.0	<10.8
259	3	>7	24	47.8	44.9	39.4	35.5	30.9	24.4	<12.9
307	5	>7	31	49.7	48.9	43.7	41.1	37.1	31.0	16.3
362	7	>7	35	52.8	53.8	47.9	45.5	41.8	36.1	21.7
396	8	>7	37	55.7	56.1	50.9	48.0	45.1	39.1	25.8

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Swirl Diffuser with Plenum Box / CSW - S 595mm x 595mm

DIFFUSER SIZE: PLENUM SIZE:

550 mm x 550 mm x 200 mm

NECK (INLET) SIZE:

Ø 145mm

TEST CON	NDITIONS					.EVEL, dB ENTRE FF				
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
73	22	0.5	21	<42.0	39.6	36.5	30.5	21.2	<14.8	<10.8
92	34	0.6	26	<44.2	45.6	42.0	37.7	30.5	19.3	<11.0
104	44	0.7	31	46.3	49.3	45.7	42.0	35.8	25.9	<11.5
120	58	0.9	35	49.2	51.5	48.7	45.1	39.3	30.3	<13.1
137	76	1.0	40	53.3	55.2	53.3	50.1	45.4	37.8	20.2

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw (vortex air distribution) in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD Swirl Diffuser with Plenum Box / CSW - S

UNIT: **DIFFUSER SIZE:**

595mm x 595mm

PLENUM SIZE:

NECK (INLET) SIZE:

550 mm x 550 mm x 200 mm Oval Neck: 255mm x 105mm

TEST CON	NDITIONS				POWER L					
Qs (L/a)	Ps (D-)	T ()	NC	125 Hz	250 Hz	500 Hz		2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
101	19	1.3	20	<42.5	40.4	36.0	28.0	18.0	<14.0	<10.8
119	26	1.6	27	<44.0	46.2	42.7	37.9	29.8	17.9	<10.9
150	40	2.1	35	47.6	51.9	49.0	45.8	39.5	29.1	<12.3
174	53	2.5	39	51.9	55.1	53.0	49.4	44.2	34.7	15.7
198	67	2.9	43	55.5	59.3	56.5	53.8	49.3	41.2	22.9

LEGEND

Qs - Primary Air Flow Rate (L/s)

Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

Horizontal Throw (vortex air distribution) in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676

This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD Swirl Diffuser with Plenum Box / CSW - S

UNIT: DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 550 mm x 550 mm x 200 mm Oval Neck: 315mm x 135mm

TEST CON	NDITIONS				POWER L					
				OCTAVE	DAIND CI	INIKETI	LQULI	101 (112)	A	
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
119	13	1.8	22	<42.6	41.3	37.7	30.3	19.6	<14.7	<10.8
138	17	2.1	27	<43.4	44.9	42.6	36.2	27.2	<16.0	<11.0
162	24	2.6	32	45.2	49.2	47.2	42.2	34.5	22.5	<11.2
188	33	3.0	36	47.6	52.6	51.0	47.0	41.3	30.6	<12.8
228	47	3.8	41	52.2	55.0	54.6	51.3	46.9	38.2	19.6

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw (vortex air distribution) in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

ViPAC

FLEX DUR TECHNOLOGY SDN BHD Swirl Diffuser with Plenum Box / CSW - S

UNIT: DIFFUSER SIZE:

595mm x 595mm

PLENUM SIZE: NECK (INLET) SIZE: 550 mm x 550 mm x 200 mm Oval Neck: 380mm x 180mm

TEST CON	NDITIONS			SOUND POWER LEVEL, dB re 1E-12w OCTAVE BAND CENTRE FREQUENCY (Hz)							
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	NAME OF TAXABLE PARTY.	2 kHz	4 kHz	8 kHz	
(2/3)	(i a)	(111)									
140	14	2.3	19	<42.1	37.4	35.2	27.9	18.3	<14.2	<10.8	
152	17	2.6	23	<42.6	39.6	38.5	32.4	22.1	<15.5	<11.5	
171	23	2.9	27	<43.7	42.2	42.5	37.0	28.2	18.3	<11.9	
200	33	3.5	32	48.1	49.2	46.5	43.0	36.2	25.7	<12.0	
224	43	4.0	36	50.8	51.6	49.2	46.4	40.6	30.2	<13.1	
262	61	4.8	41	55.3	55.6	53.4	51.5	47.4	38.8	23.3	

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw (vortex air distribution) in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Swirl Diffuser with Plenum Box / CSW - S 595mm x 595mm

DIFFUSER SIZE: PLENUM SIZE: NECK (INLET) SIZE:

550 mm x 550 mm x 250 mm Oval Neck: 420mm x 220mm

TEST CONDITIONS

SOUND POWER LEVEL, dB re 1E-12w

OCTAVE BAND CENTRE FREQUENCY (Hz)

Qs Ps T NC 125 Hz 250 Hz 500 Hz 1 kHz 2 kHz 4 kHz 8 kHz

(L/s) (Pa) (m)

155				<42.5						
164	15	4.0	24	<43.2	41.8	39.5	34.7	25.2	<16.7	<10.9
181	400.00000	The second secon		<44.4						
233	42	5.8	35	48.2	49.9	47.2	45.5	37.7	27.0	<12.1
266	60	6.7	40	51.7	53.4	52.1	50.1	44.8	34.5	16.1

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD Air Light Troffer (2 Sides) / CCLT - S - D

UNIT: SIZE:

1200mm x 600mm

NECK (INLET) SIZE:

Oval Neck: 250 x 120 mm

TEST C	ONDITIC	NS				LEVEL, CENTRE)	
Qs	Ps	T	NC	The state of the s	250 Hz	AND COMPANY OF THE	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
92	24	>4	18	<41.6	36.8	33.7	27.0	18.4	<14.5	<10.9
118	39	>4	23	<42.6	41.3	38.8	34.1	28.0	18.9	<11.1
139	54	>4	27	<43.9	45.3	42.6	38.3	33.9	26.2	<12.4
189	101	>4	36	48.9	51.8	50.0	46.5	44.7	39.4	26.5
244	169	>4	43	55.3	57.2	56.1	52.7	52.0	48.4	36.7

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

Th - Vertical Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD Air Light Troffer (4 Sides) / CCLT - S - Q

UNIT: SIZE:

600mm x 600mm

NECK (INLET) SIZE:

Oval Neck: 388 x 160 mm

TEST CO	NDITIONS			SOUND	POWER	LEVEL,	dB re 1	E-12w		
1201 001	NDI ITONO			12-1-17-7-18-00-18-7-18-7-18-7-18-7-18-7-1		CENTRE			Hz)	
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
117	19	>4	19	<43.4	36.4	32.5	31.0	21.1	<14.5	<10.7
136	26	>4	24	<44.1	39.6	36.7	36.0	29.2	18.2	<11.0
168	39	>4	31	<45.6	45.0	42.5	42.0	38.3	28.9	<13.7
210	61	>4	38	49.1	50.3	48.0	48.9	45.5	39.3	24.1
243	82	>4	42	52.9	54.0	51.4	52.8	49.4	45.9	30.8

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Vertical Throw in meters at terminal velocity of 0.25 m/s

BRYAN DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

ViPAC

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Round Diffuser / CRC - A

DIFFUSER (FACE) SIZE:

Ø 295mm

DIFFUSER (NECK) SIZE:

Ø 200mm

TEST CON	IDITIONS			SOUND POWER LEVEL, dB re 1E-12w OCTAVE BAND CENTRE FREQUENCY (Hz)						
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz		4 kHz	8 kHz
71	20	1.2	18	46.4	40.6	34.4	25.3	16.2	<13.9	<10.5
74	22	1.3	23	47.4	45.2	36.6	28.1	19.4	<14.6	<10.6
92	34	1.6	28	50.3	48.4	43.8	35.2	27.9	18.3	<10.8
107	45	1.9	33 37	53.2 55.9	50.7 52.0	48.0 52.0	40.1 46.9	33.4 41.4	23.7 32.7	<10.9 14.9
129 149	66 88	2.3	42	60.2	55.3	55.2	52.3	47.4	38.9	21.8

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL

PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Round Diffuser / CRC - A

DIFFUSER (FACE) SIZE: DIFFUSER (NECK) SIZE: Ø 345mm Ø 250mm

TEST CON	NDITIONS				POWER LE					
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
119	22	2.4	22	48.7	44.0	37.5	29.8	20.7	<15.5	<10.6
139	30	2.7	27	50.3	47.4	43.0	34.6	27.1	17.6	<10.7
154	37	3.1	32	50.6	48.9	46.7	37.5	31.2	21.0	<10.9
198	61	3.9	37	56.8	52.8	52.0	47.2	41.3	32.7	15.4
220	77	4.4	42	59.7	55.4	55.6	52.4	46.3	38.1	22.7

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Round Diffuser / CRC - A

DIFFUSER (FACE) SIZE:

Ø 395mm

DIFFUSER (NECK) SIZE:

Ø 300mm

TEST CON	NDITIONS			- CALLOS CONTROL OF THE CONTROL OF T	POWER I					
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
101 124 138 167	14 21 26 38	2.9 3.5 3.9 4.6	18 23 27 35	<44.6 46.8 47.8 51.4	40.8 44.5 45.6 48.4	32.0 38.6 42.6 49.5	22.6 29.5 33.5 40.6	<15.4 20.9 27.0 34.7	<13.8 <15.0 <17.1 25.3	<10.5 <10.5 <10.5 <11.5
214	62	5.9	41	55.6	52.0	55.5	51.4	44.6	36.1	18.5

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Linear Bar Grille / LFB - A

GRILLE (FACE) SIZE:

900mm x 95mm

TEST CON	NDITIONS				POWER L					
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(2.0)	()	()								
231	19	>7	21	<41.9	39.0	36.9	29.9	23.0	18.5	<11.7
246	22	>7	24	<43.2	39.8	39.2	32.8	26.2	21.0	<12.5
283	30	>7	28	44.1	44.7	43.3	38.6	32.4	28.5	15.9
325	40	>7	33	46.7	47.6	47.8	42.9	37.4	34.1	21.1
400	63	>7	39	53.0	51.8	53.2	48.6	44.8	42.0	29.8
	1		1000						-	

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref. 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Linear Slot Diffuser (2-slots) & Plenum Box / LFS - A

DIFFUSER (FACE) SIZE: PLENUM SIZE:

128mm (W) x 1200mm (L) 182 mm x 116 mm x 1197 mm

PLENUM NECK (INLET) SIZE:

260mm x 112mm

TEST CON	NDITIONS				POWER L					
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz
(L/s)	(Pa)	(m)								
92	26	2.4	21	<43.1	37.8	36.4	28.5	20.0	<14.6	<10.7
105	33	2.8	26	<42.8	42.3	41.3	34.4	27.3	18.0	<10.9
134	55	3.6	32	45.4	48.8	47.6	42.6	37.5	30.3	<12.7
158	77	4.3	38	48.3	53.1	52.3	47.1	43.2	37.4	18.0
183	103	5.0	42	51.6	56.6	55.9	51.2	48.1	43.7	25.3

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL
PROJECT ENGINEER

ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.



ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT:

FLEX DUR TECHNOLOGY SDN BHD

UNIT:

Linear Slot Diffuser (3-slots) & Plenum Box / LFS-A

DIFFUSER (FACE) SIZE:

175mm (W) x 1200mm (L)

PLENUM SIZE:

182 mm x 162 mm x 1197 mm

PLENUM NECK (INLET) SIZE:

315mm x 135mm

TEST CONDITIONS				SOUND POWER LEVEL, dB re 1E-12w OCTAVE BAND CENTRE FREQUENCY (Hz)							
Qs	Ps	Т	NC	125 Hz	250 Hz	500 Hz		2 kHz	4 kHz	8 kHz	
(L/s)	(Pa)	(m)									
			0.0	40.4	00.0	00.0	07.0	47.7	-11.2	<10.0	
128	20	3.8	20	<42.4	38.6	36.0	27.2	17.7	<14.3	<10.9	
160	32	4.8	25	<43.6	44.4	42.0	35.5	28.5	18.7	<11.1	
179	41	5.4	30	44.6	47.0	45.1	39.1	33.0	24.4	<11.5	
212	58	6.4	35	47.4	51.4	49.8	44.9	40.3	33.4	15.1	
259	88	>7	41	52.7	57.2	56.1	51.4	48.5	43.8	25.4	
		1		1							

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER

ZARKO DRINIC N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.

ACOUSTIC AND AIRFLOW PERFORMANCE TEST

SUPPLIED BY:

FLEX DUR TECHNOLOGY SDN BHD

TESTED BY:

VIPAC ENGINEERS & SCIENTISTS PTY LTD

TEST DATE:

MARCH 2011

CLIENT: UNIT:

FLEX DUR TECHNOLOGY SDN BHD Double Deflection Air Grille / RVD - A

GRILLE (FACE) SIZE:

600mm x 200mm

TEST CONDITIONS				SOUND POWER LEVEL, dB re 1E-12w OCTAVE BAND CENTRE FREQUENCY (Hz)							
Qs (L/s)	Ps (Pa)	T (m)	NC	125 Hz	250 Hz	500 Hz	1 kHz	2 kHz	4 kHz	8 kHz	
(L/5)	(Fa)	(111)									
282	31	6	20	44.7	38.9	36.0	30.9	26.7	22.4	<13.4	
323	54	7	25	46.6	43.6	41.0	35.8	31.5	27.7	16.3	
360	75	>7	29	50.3	46.7	44.4	39.6	34.9	31.0	19.6	
400	101	>7	33	52.6	49.7	47.9	43.4	39.0	35.0	23.6	
454	137	>7	37	57.3	52.8	51.6	47.7	43.7	40.2	27.6	

LEGEND

Qs - Primary Air Flow Rate (L/s)

Ps - Supply Static Pressure (Pa)

Insufficient margin above background noise to allow accurate determination

NC - Noise Criterion based upon room absorption of 10 dB

T - Horizontal Throw in meters at terminal velocity of 0.25m/s

BRYAN DALZIEL PROJECT ENGINEER ZARKO DRINIC

N.A.T.A. SIGNATORY

Ref: 30B-10-0406-TRP-2



NATA Accredited Laboratory Numbers: 676 This document is issued in accordance with NATA's accreditation requirements. Accredited for compliance with ISO / IEC 17025. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian / national standards.